















Demember 2009

Back²Basics

Solution

Based on Cx-3 ATC/FPT software

				Status:		Freeze alarm		Exh smoke alarm		SA smoke alarm	
				Mode:		7		8		9	
Device	Tag	Description	Reaction	Status	Result	Status	Result	Status	Result		
	BAS Computer	BAS Interface	Modulating Normal power Emergency power Alarm indicated	X X	Pass/Fail Pass/Fail	X X	Pass/Fail Pass/Fail	X X	Pass/Fail Pass/Fail		
	D-1	OA damper Modulating	Closed Open	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	D-2	Exhaust damper	Closed Open Modulating	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	S-1 Exh	Zone exhaust damper	Closed Open Modulating	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	S-1 MAU	Zone MAU Damper	Closed Open Modulating	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	EF-1	Exhaust fan	Off On Modulating	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	MAU-1	Make-up fan	Off On Modulating	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	F-1	Filter	No signal Monitoring In alarm	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	DHC-1	Dehumid coil with 2-way ATC valve	Closed Open Modulating	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	PHC-1	Preheat coil with 2-way ATC valve	Closed Open Modulating	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	RHC-1	Reheat coil with 2-way ATC valve	Closed Open Modulating	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	CO2	CO2 sensor	No signal Monitoring In alarm	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	DA-T	Disch air transmitter	No signal Monitoring In alarm	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		
	FZ-1	Freeze-stat	No signal Monitoring In alarm	X	Pass/Fail	X	Pass/Fail	X	Pass/Fail		