



Operator's Work Station

BACnet IP



Building Controller

BACnet MS/TP



Application Specific Controller

DO

AO

EIA-485

*Speed References
(or via BACnet)*

*BACnet MS/TP
(see table below)*



Variable Frequency Drive

Safeties

Overpressure

:

:

:

Firestat

Freezstat

Run/Stop Command

Run/Stop Feedback

Speed Command

Speed Feedback

Motor Amps

Power

kW Hr (resettable)

Operating Hrs (R)

:

:

:

OK/Fault